



Certificate of Compliance

Certificate: 80012071

Master Contract: 300557

Project: 80012071

Date Issued: 2019-08-22

Issued To: Ariel Technology Inc.
9- 1111 Gorham Street
Newmarket, Ontario, L3Y 8X8
Canada

Attention: Ali Malekpour

The products listed below are eligible to bear the CSA Mark shown

Issued by: Grace Gao
Grace Gao



PRODUCTS

CLASS - C482351 - TEMPERATURE INDICATING AND REGULATING EQUIPMENT Appliance Type
Controls - Temperature Controls

CLASS - C482387 - TEMPERATURE-INDICATING AND REGULATING EQUIP.-Appliance Type
Temperature Controls-Cert to US Stds

Operation control, thermostat, models TTEC-100 and TTEC-200, 125Vac, 60Hz, 15A; 30,000 cycles; Operation ambient temperature: -20°C to 80°C

Hygrostat, model HYTEC-100, 120/240Vac, 12 /6A resistive; 10/5 FLA, 45/22.5 LRA, inductive; 30,000 cycles; Operation ambient temperature: 10°C to 40°C

Note:

1. The controls above have not been evaluated for safety or limiting applications or to provide protection for the connected loads.
2. The controls above are evaluated as component only which shall be installed in compliance with the enclosure, mounting, spacing, and segregation requirements of the ultimate application.



APPLICABLE REQUIREMENTS

CSA requirements:

CAN/CSA-E60730-1:15 - Automatic Electrical Controls for Household and Similar Use - Part 1: General Requirements - Third Edition

CAN/CSA-E60730-2-9:15 - Automatic Electrical Controls for Household and Similar Use - Part 2-9: Particular Requirements for Temperature Sensing Controls - Second Edition

UL requirements:

UL 60730-1 - Automatic Electrical Controls for Household and Similar Use; Part 1: General Requirements - Fifth Edition

UL 60730-2-9 - Automatic Electrical Controls for Household and Similar Use; Part 2: Particular Requirements for Temperature Sensing Controls - Fourth Edition

UL 60730-2-13 - Automatic Electrical Controls for Household and Similar Use; Part 2: Particular Requirements for Humidity Sensing Controls - Third Edition